

SECTION A–A

SHOWER WALL AT THE FLOOR – BATHROOM / LAUNDRY TO SHOWER (NTS)




VIEW B–B

ELEVATION ON THE SHOWER WALL – MEMBRANE HEIGHTS (NTS)



DETAIL C

SHOWER WALL / FLOOR JUNCTION – ENLARGED (NTS)



NOTES

1. AS 3740 ROUTE (NCC H4D3(b)(i)); HP 10.2.1–10.2.6 EXTENTS + 10.2.12 FALLS APPLY ON BOTH ROUTES. READ WITH AS 3740, THE FORSPEC SPECIFICATION AND CURRENT TDS. LABELS GENERIC – MEMBRANES AS SPECIFIED.
2. MEMBRANE 1 (UNDER SCREED) AND MEMBRANE 2 (WALLS): APPROVED FORSPEC LIQUID MEMBRANE SYSTEMS. PRIMER, COATS AND MIN DFT PER THE TDS.

STAGE 1 – BEFORE SCREED

3. WET-AREA GRADE FC FLOOR SHEETING FIXED PER THE SHEET MAKER, TO FALL MIN 1:100 TO EACH WASTE (AS 3740 CL 2.3.1), JOINTS SEALED AND BANDAGED (B107).
4. DRAINAGE FLANGE AT EACH WASTE: FLUSH, FIXED, SEALED TO THE RISER, SEALANT AT ITS EDGE (AS 3740 CL 4.3.1). PRIME. 12mm SEALANT FILLETS AT FLOOR / WALL (CLASS III; II 35, I 100mm – TABLE 4.10).
5. APPLY MEMBRANE 1 OVER THE FC FLOOR, ONTO THE FLANGE TO THE RISER, AND UP ALL WALLS MIN 150mm ABOVE FFL.
6. FLOOD TEST MEMBRANE 1 AFTER CURE. SLIP SHEET + MIN SCREED PER THE TDS.

STAGE 2 – SCREED AND WALLS

7. WASTE BODY IN THE RISER, WEEP HOLES AT THE FLANGE. FORSPEC ENGINEERED SCREED TO FALLS, CURED.
8. MEMBRANE 2 OVER THE WHOLE SHOWER WALL FACE (NOT JUST JUNCTIONS) TO 1800mm ABOVE FFL, OR 50mm ABOVE THE ROSE IF HIGHER; CORNERS 40mm MIN EACH SIDE (HP 10.2.2; AS 3740 CL 4.6.3(c)); LAPPED OVER THE MEMBRANE 1 UPTURN TO THE SCREED TOP.

STAGE 3 – TILING

9. TILE WITH FORSPEC TILE ADHESIVE. 6mm MIN FLEXIBLE SEALANT JOINT AT WALL / FLOOR TILE.

GENERAL

10. FALLS MIN 1:80, MAX 1:50 TO THE WASTES, NO PONDING (NCC HP 10.2.12; VOL ONE F2D4).
11. HOLD POINT: PHOTOS OF FILLETS, BANDAGES, COATS (WFT) AND FLOOD TESTS.
12. AMENDED FROM THE ORIGINAL TO COMPLY: BATHROOM FALL MIN 1:80 (NCC HP 10.2.12); SUBSTRATE FALL 1:100 (AS 3740 CL 2.3.1); DRAINAGE FLANGE (HP 10.2.29).
13. FORSPEC MAY REQUIRE AN ALTERNATE WATERSTOP BASED ON DESIGN CONDITIONS.

FORSPEC® PROTECTIVE COATINGS

BATHROOM ON FC SHEETING – UNDERSCREED MEMBRANE AT SHOWER WALL

FORSPEC STANDARD DETAIL - SUPERSEDES B104 REV C

COPYRIGHT. ALL RIGHTS RESERVED. CANNOT BE REPRODUCED OR COPIED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF FORSPEC. ANY LICENSE EXPRESSED OR IMPLIED, TO USE THIS DOCUMENT FOR ANY PURPOSE WHATSOEVER IS RESTRICTED TO THE TERMS OF THE AGREEMENT

SCALE	DRAWING No	REFERENCE	REVISION
NTS	B104	B104 REV C	E
DATE	DESIGNED BY	DRAWN	CHECKED
09/11/2026	JG	JG	—