

SECTION A–A

SHOWER BASE ON A MORTAR BED AT THE WALL (NTS)




VIEW B–B

ELEVATION ON THE WALL AT THE BASE – TILES CUT BACK (NTS)



DETAIL C

ANGLE FOOT, FIXING AND SEALANT – ENLARGED (NTS)



NOTES

1. AS 3740 ROUTE (NCC H4D3(b)(i)): HP 10.2.1–10.2.6 EXTENTS + 10.2.12 FALLS APPLY ON BOTH ROUTES. READ WITH AS 3740, THE FORSPEC SPECIFICATION AND CURRENT TDS. LABELS GENERIC – MEMBRANES AS SPECIFIED.

STAGE 1 – FLOOR

2. FIX THE ALUMINIUM ANGLE TO THE FC SHEETING FLOOR AGAINST THE FRAMING. FORSPEC JOINT SEALANT 1 OVER THE FIXING AND AT THE FLANGE END.
3. PRIME (FORSPEC PRIMER 1). FORSPEC MEMBRANE 1 UP THE ANGLE FACE, OVER THE FLANGE AND THE SEALANT AND OVER THE FLOOR.

STAGE 2 – SHOWER BASE

4. BED THE SHOWER BASE ON MORTAR WITH ITS UPSTAND AGAINST THE ANGLE. WASTE RISER JOINED TO THE BASE WITH A WATERPROOF JOINT (NCC HOUSING PROVISIONS 10.2.30(1)).

STAGE 3 – WALL

5. FORSPEC PRIMER 2 + MEMBRANE 2 ON THE FC WALL LINING, WHICH PASSES DOWN INSIDE THE UPSTAND LIP (NCC HOUSING PROVISIONS 10.2.19), DOWN ONTO THE LIP. FORSPEC JOINT SEALANT 2 UNDER THE LINING.
6. MEMBRANE 2 OVER THE WHOLE SHOWER WALL FACE, NOT JUST THE JUNCTIONS, TO MIN 1800mm ABOVE THE BASE OR 50mm ABOVE THE ROSE, WHICHEVER IS HIGHER, CORNERS MIN 40mm EACH SIDE (NCC HP 10.2.2; AS 3740 CL 4.6.3(c)).
7. CERAMIC TILES ON FORSPEC TILE ADHESIVE WITH WET AREA SEALANT AT THE LIP.

GENERAL

8. HOLD POINT: INSPECTION AND PHOTOS OF THE ANGLE, FIXINGS AND EACH COAT (WFT) BEFORE THE FIXTURE GOES IN.
9. AMENDED FROM THE ORIGINAL TO COMPLY: THE FIXING THROUGH THE ANGLE FLANGE IS WATERPROOFED WITH FLEXIBLE SEALANT COMPATIBLE WITH THE MEMBRANE (AS 3740 CL 4.12.1, 4.12.3).
10. FORSPEC MAY REQUIRE AN ALTERNATE WATERSTOP BASED ON DESIGN CONDITIONS.

FORSPEC® PROTECTIVE COATINGS

SHOWER BASE

FORSPEC STANDARD DETAIL - SUPERSEDES B113 REV C

COPYRIGHT. ALL RIGHTS RESERVED. CANNOT BE REPRODUCED OR COPIED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF FORSPEC. ANY LICENSE EXPRESSED OR IMPLIED, TO USE THIS DOCUMENT FOR ANY PURPOSE WHATSOEVER IS RESTRICTED TO THE TERMS OF THE AGREEMENT

SCALE	DRAWING No	REFERENCE	REVISION
NTS	B113	B113 REV C	E
DATE	DESIGNED BY	DRAWN	CHECKED
09/11/2026	JG	JG	—