

INTERNAL ELEVATION A

DEVELOPED VIEW OF TANK CORNER – AFS WALL / CONCRETE WALL / FLOOR (NTS)




SECTION B–B

WALL / FLOOR JUNCTION – ENLARGED (NTS)



DETAIL C

AFS PANEL JOINT – ENLARGED PLAN (NTS)



NOTES

1. READ WITH BGL012, FORSPEC BGL006 / BGL007, THE LIQUID MEMBRANE, COVE MORTAR, HYDROPHILIC WATERSTOP AND HYDROPHILIC SEALANT TDS AND THE ARCH./STRUCTURAL DRAWINGS. WALL TYPES, BARS, COVER AND JOINTS ARE BY THE ENGINEER.

STAGE 1 – BEFORE CONCRETE WALL POUR

2. FIX HYDROPHILIC WATERSTOP 20x10 TO THE CLEAN, DRY AFS FACE AT EVERY AFS / CONCRETE WALL JOINT AND AT THE WALL / FLOOR CJ, CENTRED WITH MIN 75mm COVER BOTH SIDES. BUTT JOINTS ONLY.
3. SEAL EVERY BAR CROSSING THE JOINT WITH FORSPEC HYDROPHILIC SEALANT (10x10 BEAD) AT THE JOINT FACE. BARS GALVANISED OR EPOXY COATED (REFER STRUCT.).

STAGE 2 – TANK LINING (CONCRETE MIN 28 DAYS)

4. PREPARE ALL SURFACES: SOUND, CLEAN, NO LAITANCE, FORM OIL OR CURING COMPOUND. REPAIR WITH FORSPEC REPAIR MORTAR. TEST AREA ON AFS FACE.
5. FORM COVE MORTAR 35x35 COVES TO ALL INTERNAL CORNERS: WALL / WALL (FULL HEIGHT), WALL / FLOOR AND WALL / SOFFIT.
6. 1ST COAT FORSPEC LIQUID MEMBRANE MIN 100mm EACH SIDE OF COVES AND AFS PANEL JOINTS; EMBED FORSPEC BANDAGE CENTRALLY WHILE WET, 50mm LAPS, FULLY ENCAPSULATED.
7. FORSPEC LIQUID MEMBRANE TO FLOOR, WALLS AND SOFFIT: 3 COATS, MIN 1.5mm DFT (0.77mm WFT/COAT), ALTERNATE DIRECTIONS, RECOAT MIN 24 HRS.
8. CURE MIN 10 DAYS WITH MECHANICAL VENTILATION BEFORE FILLING.

GENERAL

9. KEEP HYDROPHILIC WATERSTOP DRY UNTIL CONCRETE IS PLACED. REPLACE ANY STRIP THAT HAS SWOLLEN.
10. HOLD POINT: WATERPROOFING INSPECTION AND PHOTOS OF HYDROPHILIC WATERSTOP, BAR SEALS, COVES AND MESH; WFT READINGS EACH COAT.
11. NOT FOR POTABLE WATER WITHOUT WRITTEN FORSPEC CONFIRMATION (NO AS/NZS 4020 APPROVAL CLAIMED).
12. ACTIVE LEAKS: STOP WITH FAST-SETTING PLUGGING MORTAR FIRST, THEN COMPLETE WITH COVE MORTAR.
13. FORSPEC MAY REQUIRE AN ALTERNATE WATERSTOP BASED ON DESIGN CONDITIONS.

FORSPEC® PROTECTIVE COATINGS

RAINWATER TANK – INTERNAL ELEVATION
WALL AND FLOOR JUNCTIONS

FORSPEC STANDARD DETAIL - SUPERSEDES BGL013 REV A

COPYRIGHT. ALL RIGHTS RESERVED. CANNOT BE REPRODUCED OR COPIED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF FORSPEC. ANY LICENSE EXPRESSED OR IMPLIED, TO USE THIS DOCUMENT FOR ANY PURPOSE WHATSOEVER IS RESTRICTED TO THE TERMS OF THE AGREEMENT

SCALE	DRAWING No	REFERENCE	REVISION
NTS	BGL013	BGL012 / BGL006	B
DATE	DESIGNED BY	DRAWN	CHECKED
11/11/2026	JG	JG	—