VOC Content Test Certificate

Thursday 16th October 2025

Supplier: FORSPEC PROTECTIVE COATINGS (22/872 Canterbury Rd, Roselands, NSW 2196, AUSTRALIA).

Product name: FORSPEC ACTFLEX 929 HV

Date Tested: 7 October 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.3-13.1.1B** **Green Star Interiors V1.3-12.1.1B**	**FORSPEC ACTFLEX 929 HV**
Water Proofing Membranes and Sealant Limit: **250 grams per litre**	**137 grams per litre as VOC content per material**
We hereby certify FORSPEC ACTFLEX 929 HV is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 16/10/2025 **Expiry date: 16/10/2030** **P25100001**