CETEC Pty Ltd ABN 44 006 873 687
Melbourne | Sydney | Brisbane | Perth | London | San Francisco

VOC Content Test Certificate

Monday 25th August 2025

Supplier: FORSPEC PROTECTIVE COATINGS Pty Ltd (22/872 Canterbury Rd, Roselands, NSW, 2196, AUSTRALIA).

Product Name: ACTFLEX 989 CWP

Date Tested: 22nd August 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.3-13.1.1B** **Green Star Interiors V1.3-12.1.1B**	**ACTFLEX 989 CWP**
Acoustic Sealants, Architectural Sealant, Water Proofing Membranes and Sealant Limit: 250 grams per litre	**4 grams per litre as VOC content per material**
We hereby certify ACTFLEX 989 CWP is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 25/08/2025 **Expiry date: 25/08/2030** **P25080121**