VOC Content Test Certificate

Friday 29th May 2026

Supplier: FORSPEC PROTECTIVE COATINGS (22/872 Canterbury Rd, Roseland, NSW, 2169, AUSTRALIA).

Product name: ACTFLEX BIOSET

Date Tested: 29th May 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.3-13.1.1B** **Green Star Interiors V1.3-12.1.1B**	**ACTFLEX BIOSET**
General Purpose Adhesive and Sealant Limit: **50 grams per litre**	**1 gram per litre as VOC content per material**
We hereby certify ACTFLEX BIOSET is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 29/05/2026 **Expiry date: 29/05/2031** **P26050125**